

Central Kitsap School District  
Underground Storage Tanks  
8/11/16

**I. Central Kitsap High School**

Address:

3700 NW Anderson Hill Road  
Silverdale, WA 98383

1. Waste Oil Storage Tank- ACTIVE

Description:

300 Gallon Underground Storage Tank (UST)  
Located on West side of auto shop  
Used for waste oil from the auto shop  
Installed 10/15/97  
(replaced a 550 gallon waste oil tank that was removed)

2. Two 8,000 gallon heating oil tanks – Closed in place in 2005.  
Located next to boiler room.

**II. Transportation Department (Three Tanks)**

Address:

10170 Frontier Place NW  
Silverdale, WA 98383

1. One Waste Oil Storage Tank - ACTIVE

Description:

1,100 Gallon UST  
Located on East side of building  
Used for waste oil from the shop  
Installed 10/13/97

2. One Unleaded Gasoline Storage Tank - ACTIVE

Description:

12,000 Gallon UST  
Located on North side of building  
Used for dispensing for District busses and vehicles  
Installed 1977; Upgraded 9/5/1997

- A. One Diesel Storage Tank - ACTIVE

Description:

12,000 Gallon UST  
Located on North side of building

Central Kitsap School District  
Underground Storage Tanks  
8/11/16

Used for dispensing for District busses and vehicles  
Installed 1977; Upgraded 9/5/1997

**II. Science Kit Building (former Maintenance building; Former bus garage)**

Address:

3790 NW Anderson Hill Road  
Silverdale, WA 98383

Described as in “Lower yard by old gas pumps”

1000 gallon unleaded gasoline UST. Closed in place with sand & concrete slurry 1990.

1000 gallon diesel UST (some notes say 3,000 gallons)

400 gallon waste oil UST. Notes indicated filled in place.

**III. Central Kitsap Middle School**

1. One 8,000 gallon heating oil UST – Notes indicate it was closed in place with sand and concrete slurry. Located east of boiler room.
2. One 675 diesel oil UST shown on drawing next to the 8,000 gallon tank. No other records found for this tank.
3. *Other - 2013 sinkhole in main parking lot could have been an old well (3 ft diameter)*
4. *Other – Original water supply to CK Middle was from a well located near what are now the baseball fields. A vault is likely located there.*

**IV. Olympic High School**

Address:

7070 Stampede Boulevard NW  
Bremerton, WA 98311

1. Waste Oil Storage Tank- Inactive - Temporary closure

Description:

300 Gallon Underground Storage Tank (UST)

Located on West side of auto shop

Was used for waste oil from the auto shop

Installed 10/15/97 (replaced a 550 gallon waste oil tank that was removed)

Central Kitsap School District  
Underground Storage Tanks  
8/11/16

**V. Seabeck Elementary School**

Address:

15565 Seabeck Highway NW  
Seabeck, WA 98380

1. One 5,000 gallon heating oil UST –Located east of multipurpose room.  
Not filled in place.

**VI. Jenne Wright Administration Building**

1. One 1,500 gallon heating oil UST –Located in back (west) parking lot. Reported to be closed in place.